



SUMMARY INFORMATION ON UNDERGROUND STORAGE TANKS

North Dakota Department of Health - Division of Waste Management
Telephone: 701.328.5166 Fax: 701.328.5200 Web site: www.ndhealth.gov/wm
Public Notice Rev.: 04/2008



General Information

Total Number of UST Facilities: 1026

Public Record Posted Date: 10/01/2010

Total Number of USTs: 2316

Reporting Period Dates: 10/01/2009 to 09/30/2010

Summary Information For On-Site Inspections

Number of UST Facilities Inspected: 307

Percent Compliance: 83.71%

Summary Information For Release

Number of Confirmed UST Releases: 4

Summary Information For Release Sources and Causes

Source			Cause													
			Spill		Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
Piping	2	25.0	0	0.0	0	0.0	0	0.0	2	100.0	0	0.0	0	0.0	0	0.0
Dispenser	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
STP	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
Delivery Problem	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
Other	6	75.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	6	100.0
Totals	8	100.0	0	0.0	0	0.0	0	0.0	2	100.0	0	0.0	0	0.0	6	100.0

= Number of releases

% = Percent of total number of Source

Note: Release, sources and causes information are based on USTs as defined in NDAC Section 33-24-08-40. Source and cause data is collected from information provided through release reporting as required in NDAC Section 33-24-08-40. Site specific UST information on compliance and releases can be obtained upon request.